

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 11:55 am

**PWS ID:** UTAH09004      **Name:** ESCALANTE TOWN WATER SYSTEM  
**Legal Contact:** ESCALANTE      **Rating:** Approved  
 GUY GRAHAM      **Rating Date:** 03/10/1980  
**Address:** BOX 189      **Activity Status:** Active  
 ESCALANTE, UT 84726  
**Phone Number:** 435-826-4644  
**City Served (Area):**  
**County:** GARFIELD COUNTY

**System Type:** Community      **Last Inv Update:** 07/28/2010      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 08/10/2009      **Total Dsgn Cap:**  
**Population:** 1,000      **Surveyor:** ELDEN L OLSEN      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

Gal/Day    Gal/Min

### Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	GRAHAM, GUY		435-826-4644	435-826-4358	escalant@scinternet.net

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	584
			584    Total Svc Connections

### Storage

**Total Storage:** 1,000,000 GAL      **Number of Units:** 2      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STEEL TANK	Ground	500,000 GAL	Steel	0	A	
ST002	CONCRETE TANK	Ground	500,000 GAL	Concrete	0	A	

### Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	CYN 14-17 MI NO CHLORINATOR		A	
TP002	FE-MN REMOVAL PLANT		P	

### Distribution System

Pump Type	Total Dyn Head ft H2O    P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	CYN 14-17 MI NO SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	CITY WELL	Active	WL		250 GPM		Yes	GW	Permanent	1/1 to 12/31	
WS003	LOST CREEK SPRING	P	SP				No	GU	Permanent		

\*Reports measured flow for wells, approved design capacity for all other sources.